



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
ONSITE SEWAGE TREATMENT AND DISPOSAL  
SYSTEM

PERMIT #: 53-SB-2667961  
APPLICATION #: AP1952508  
DATE PAID: \_\_\_\_\_  
FEE PAID: \_\_\_\_\_  
RECEIPT #: \_\_\_\_\_  
DOCUMENT #: PR1979009

CONSTRUCTION PERMIT FOR: OSTDS New  
APPLICANT: Enrique Fernandez  
PROPERTY ADDRESS: 0 Doc Lindsey Rd Fort Meade, FL 33841  
LOT: NA BLOCK: NA SUBDIVISION: N/A  
PROPERTY ID #: 263123-000000-011010 [SECTION, TOWNSHIP, RANGE, PARCEL NUMBER]  
[OR TAX ID NUMBER]

SYSTEM MUST BE CONSTRUCTED IN ACCORDANCE WITH SPECIFICATIONS AND STANDARDS OF SECTION 381.0065, F.S., AND CHAPTER 64E-6, F.A.C. DEPARTMENT APPROVAL OF SYSTEM DOES NOT GUARANTEE SATISFACTORY PERFORMANCE FOR ANY SPECIFIC PERIOD OF TIME. ANY CHANGE IN MATERIAL FACTS, WHICH SERVED AS A BASIS FOR ISSUANCE OF THIS PERMIT, REQUIRE THE APPLICANT TO MODIFY THE PERMIT APPLICATION. SUCH MODIFICATIONS MAY RESULT IN THIS PERMIT BEING MADE NULL AND VOID. ISSUANCE OF THIS PERMIT DOES NOT EXEMPT THE APPLICANT FROM COMPLIANCE WITH OTHER FEDERAL, STATE, OR LOCAL PERMITTING REQUIRED FOR DEVELOPMENT OF THIS PROPERTY.

SYSTEM DESIGN AND SPECIFICATIONS

T [ 4,800 ] GALLONS / GPD New Septic Tank W/ Baffle & Filter CAPACITY  
A [ ] GALLONS / GPD \_\_\_\_\_ CAPACITY  
N [ ] GALLONS GREASE INTERCEPTOR CAPACITY [MAXIMUM CAPACITY SINGLE TANK:1250 GALLONS]  
K [ 3,000 ] GALLONS DOSING TANK CAPACITY [366.67] GALLONS @ [ 6 ] DOSES PER 24 HRS #Pumps [ 2 ]  
D [ 5,000 ] SQUARE FEET Low Pressure Dose SYSTEM  
R [ ] SQUARE FEET \_\_\_\_\_ SYSTEM  
A TYPE SYSTEM: [ ] STANDARD [x] FILLED [ ] MOUND [ ] \_\_\_\_\_  
I CONFIGURATION: [x] TRENCH [ ] BED [ ] \_\_\_\_\_

F LOCATION OF BENCHMARK: Red Dot Side of the Road  
I ELEVATION OF PROPOSED SYSTEM SITE [ 3.00 ] [ INCHES / FT ] [ ABOVE / BELOW ] BENCHMARK/REFERENCE POINT  
E BOTTOM OF DRAINFIELD TO BE [ 4.00 ] [ INCHES / FT ] [ ABOVE / BELOW ] BENCHMARK/REFERENCE POINT  
L  
D FILL REQUIRED: [ 17.00 ] INCHES EXCAVATION REQUIRED: [ ] INCHES

O  
T  
H  
E  
R  
Each pump serves 1/2 of required absorption area pumps to dose alternately.  
Pumps must be certified as suitable for distributing sewage effluent.  
PE Design Required.

SPECIFICATIONS BY: Andrew R Britt TITLE: P.E. #83216  
APPROVED BY: Matthew A Nickerson TITLE: Environmental Manager Polk CHD  
DATE ISSUED: 07/18/2023 EXPIRATION DATE: 01/18/2025

## NOTICE OF RIGHTS

A party whose substantial interest is affected by this order may petition for an administrative hearing pursuant to sections 120.569 and 120.57, Florida Statutes. Such proceedings are governed by Rule 28-106, Florida Administrative Code. A petition for administrative hearing must be in writing and must be received by the Agency Clerk for the Department, within twenty-one (21) days from the receipt of this order. The address of the Agency Clerk is 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, Florida 32399-3000. The Agency Clerk's email is [agency\\_clerk@FloridaDEP.gov](mailto:agency_clerk@FloridaDEP.gov).

Mediation is not available as an alternative remedy.

Your failure to submit a petition for hearing within 21 days from receipt of this order will constitute a waiver of your right to an administrative hearing, and this order shall become a 'final order'.

Should this order become a final order, a party who is adversely affected by it is entitled to judicial review pursuant to Section 120.68, Florida Statutes. Review proceedings are governed by the Florida Rules of Appellate Procedure. Such proceedings may be commenced by filing one copy of a Notice of Appeal with the Agency Clerk of the Department of Environmental Protection and a second copy, accompanied by the filing fees required by law, with the Court of Appeal in the appropriate District Court. The notice must be filed within 30 days of rendition of the final order.

0-Joe Lindsey Rd  
Ft Meade FL



STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
ONSITE SEWAGE TREATMENT AND DISPOSAL SYSTEM

PERMIT NO. \_\_\_\_\_

SITE EVALUATION AND SYSTEM SPECIFICATIONS

APPLICANT: Enrique Fernandez AGENT: Integrity Permit Solutions  
LOT: N/A BLOCK: N/A SUBDIVISION: N/A  
PROPERTY ID #: 263123-000000-011010 [Section/Township/Parcel No. or Tax ID Number]

TO BE COMPLETED BY ENGINEER, HEALTH DEPARTMENT EMPLOYEE, OR OTHER QUALIFIED PERSON. ENGINEERS MUST PROVIDE REGISTRATION NUMBER AND SIGN AND SEAL EACH PAGE OF SUBMITTAL. COMPLETE ALL ITEMS.

PROPERTY SIZE CONFORMS TO SITE PLAN: [] YES [ ] NO NET USABLE AREA AVAILABLE: 12.11 ACRES  
TOTAL ESTIMATED SEWAGE FLOW: 760 GALLONS PER DAY [TABLE I / OTHER]  
AUTHORIZED SEWAGE FLOW: 18165 GALLONS PER DAY [1500 GPD/ACRE OR 2500 GPD/ACRE]  
UNOBSTRUCTED AREA AVAILABLE: 1500T SQFT UNOBSTRUCTED AREA REQUIRED: 1425 SQFT  
R.P. = 52"  
BENCHMARK/REFERENCE POINT LOCATION: Red dot side of the Rd  
ELEVATION OF PROPOSED SYSTEM SITE IS 3 [INCHES/FT] [~~ABOVE~~ BELOW] BENCHMARK/REFERENCE POINT

THE MINIMUM SETBACK WHICH CAN BE MAINTAINED FROM THE PROPOSED SYSTEM TO THE FOLLOWING FEATURES  
SURFACE WATER: N/A FT DITCHES/SWALES: \_\_\_\_\_ FT NORMALLY WET? [ ] YES [] NO  
WELLS: PUBLIC: N/A FT LIMITED USE: N/A FT PRIVATE: 75 FT NON-POTABLE: N/A FT  
BUILDING FOUNDATIONS: 7 FT PROPERTY LINES: 10 FT POTABLE WATER LINES: 30 FT

SITE SUBJECT TO FREQUENT FLOODING: [ ] YES [] NO 10 YEAR FLOODING? [ ] YES [] NO  
10 YEAR FLOOD ELEVATION FOR SITE: N/A FT MSL/NGVD SITE ELEVATION: N/A FT MSL/NGVD

SOIL PROFILE INFORMATION SITE 1 = 55

SOIL PROFILE INFORMATION SITE 2 = 56

MUNSELL #/COLOR	TEXTURE	DEPTH
104R 411	FS	0 TO 6
104R 512	FS	6 TO 12
104R 412	FS	12 TO 25
104R 512	FS	25 TO 30
104R 413	FS	30 TO 40
104R 612	FS	40 TO 45
104R 713	FS	45 TO 60
104R 712	FS	60 TO 72
		TO

USDA SOIL SERIES: Nalcoossee like

MUNSELL #/COLOR	TEXTURE	DEPTH
104R 411	FS	0 TO 8
104R 512	FS	8 TO 14
104R 412	FS	14 TO 24
104R 512	FS	24 TO 32
104R 413	FS	32 TO 41
104R 612	FS	41 TO 46
104R 713	FS	46 TO 61
104R 712	FS	61 TO 72
		TO

USDA SOIL SERIES: Nalcoossee like

map as D46te  
OBSERVED WATER TABLE: 60 INCHES [~~ABOVE~~ BELOW] EXISTING GRADE. TYPE: [~~PERCHED~~ APPARENT]  
ESTIMATED WET SEASON WATER TABLE ELEVATION: 25 INCHES [~~ABOVE~~ BELOW] EXISTING GRADE  
HIGH WATER TABLE VEGETATION: [ ] YES [] NO WSWT INDICATOR: [] YES [ ] NO DEPTH: 25 INCHES

SOIL TEXTURE/LOADING RATE FOR SYSTEM SIZING: FS .8 DEPTH OF EXCAVATION: N/A INCHES  
DRAINFIELD CONFIGURATION: [] TRENCH [ ] BED [ ] OTHER (SPECIFY) \_\_\_\_\_  
REMARKS/ADDITIONAL CRITERIA: \_\_\_\_\_

104R 612 stripping at 25" in 104R 512 matrix at site 2

SITE EVALUATED BY: JAFAR YOUSEFI CEHP DATE: 3/4/23  
DEP 4015, 06-21-2022 (Obsoletes previous editions which may not be used)

VACANT - GEODE

220'

N



1730'

W. Ghafar  
CEHP  
JAFAR YOUSEFI

3/4/23

25'

5000  
SF  
10 BR

200'

Gravel

310'

FIAT

30'

5-2

40'

8 Panels  
8 Piers



10'



75-1

30'

Proposed  
N12

75'

1.56 ACRE OUT OF

12.11 ACRES

NORTH OF PROPERTY

D. Way

150 TO  
DITCH

Well  
(PROPOSED)

Dry  
Ditch

RP

V  
A  
C  
A  
N  
T



STATE OF FLORIDA  
 DEPARTMENT OF HEALTH  
 ONSITE SEWAGE TREATMENT AND DISPOSAL  
 SYSTEM  
 APPLICATION FOR CONSTRUCTION PERMIT

*Integrity Permit*  
*863-308-4682*

PERMIT NO. 2667961  
 DATE PAID: \_\_\_\_\_  
 FEE PAID: \_\_\_\_\_  
 RECEIPT #: \_\_\_\_\_

APPLICATION FOR:

New System       Existing System       Holding Tank       Innovative  
 Repair       Abandonment       Temporary       \_\_\_\_\_

APPLICANT: Enrique Fernandez

AGENT: HAYCOR, LLC Andrew Britt, P.E.#83216      TELEPHONE: 863-581-4485

MAILING ADDRESS: 3736 Knights Station Road, Lakeland, FL 33810 andrew.wbeng@gmail.com

*integritypermitrunner@gmail.com*

TO BE COMPLETED BY APPLICANT OR APPLICANT'S AUTHORIZED AGENT. SYSTEMS MUST BE CONSTRUCTED BY A PERSON LICENSED PURSUANT TO 489.105(3) (m) OR 489.552, FLORIDA STATUTES. IT IS THE APPLICANT'S RESPONSIBILITY TO PROVIDE DOCUMENTATION OF THE DATE THE LOT WAS CREATED OR PLATTED (MM/DD/YY) IF REQUESTING CONSIDERATION OF STATUTORY GRANDFATHER PROVISIONS.

PROPERTY INFORMATION

LOT: --      BLOCK: --      SUBDIVISION: --      PLATTED: --

PROPERTY ID #: 26-31-23-000000-011010      ZONING: Res      I/M OR EQUIVALENT:  Y /  N ]

PROPERTY SIZE: 12.11 ACRES      WATER SUPPLY:  PRIVATE      PUBLIC  ]<=2000GPD  >2000GPD

IS SEWER AVAILABLE AS PER 381.0065, FS?  Y /  N ]      DISTANCE TO SEWER: -- FT

PROPERTY ADDRESS: 0 Doc Lindsey Road, Fort Meade, FL 33841

DIRECTIONS TO PROPERTY: \_\_\_\_\_

BUILDING INFORMATION       RESIDENTIAL       COMMERCIAL

Unit No	Type of Establishment	No. of Bedrooms	Building Area Sqft	Commercial/Institutional System Design Table 1, Chapter 64E-6, FAC
1	Work Camp			80 workers @ 50 gpd
2				4,000 gpd Total
3				
4				

Floor/Equipment Drains       Other (Specify) \_\_\_\_\_

SIGNATURE: *Andrew Britt*      DATE: 7-5-23